




ICONICS V10.71 Resolved Issues

October 2012



2012 PARTNER OF THE YEAR
Sustainability
Winner



Microsoft Partner
Gold Independent Software Vendor (ISV)



Contents

Platform Services	2
BACnet	2
FrameWorX	2
Global Aliasing.....	2
Installation	2
Language Aliasing.....	2
Pack and Go	3
Security	3
Unified Data Manager.....	3
Workbench Silverlight.....	3
Workbench Classic	3
GENESIS64.....	3
General.....	3
AlarmWorX64.....	4
AssetWorX.....	5
GraphWorX64	5
GridWorX	6
ScheduleWorX64.....	6
TrendWorX64.....	6

Platform Services

BACnet

26105	An issue with Signed Integers that was causing more data to be stored than necessary, but this has been resolved.
26640	An issue that caused the BACnet Runtime to fail in rare cases was fixed. This issue was related to communication with the License Service.
26703	An issue in the BACnet Runtime that prevented BBMD support from running properly was addressed.

FrameWorX

25957	Issues related to reading data from a FrameWorX Server that was using a Third-Party OPC Server through ICONICS Security have been fixed to allow for faster and more efficient data transfer.
26587	An issue with the Redundancy Viewer in Workbench could cause a rare crash in FrameWorX Server when combined with a specific scenario, but this has been resolved.
25337	An issue caused by MonitorWorX that caused problems with browsing OPC Classic servers when Hyper Historian or AnalytiX was installed on top of GENESIS64 has been fixed.
25537	An issue has been resolved that was caused by user latency could cause the FrameWorX Server to timeout when trying to read the Language Aliasing Server.
25254	A leak was detected and fixed in the GridWorX Server/Viewer when it was set to periodic refresh while switching GraphWorX64 displays.

Global Aliasing

16874	Automatic case handling for 10.61 > 10.71 imports regarding Global Aliasing has been resolved and allows for easier upgrade of the Global Aliasing Server.
25300	An issue with the upgrade ability of the Global Aliasing Server has been fixed to allow upgrade from previous versions without issues.

Installation

26174	An issue was fixed while upgrading from previous versions could break functionality of configured Triggers used from the Unified Data Manager to control BizViz v9.22 products.
-------	---

Language Aliasing

24541	An issue with Language Aliasing when the folder structure contained three or more levels has been fixed regarding the AlarmWorX64 Server.
24151	An issue in the Language Aliasing Server that related to copying a Translation has been fixed to not include the Language Name on the clipboard when copied.

Pack and Go

26040	Validation has been added to the Unpack dialog of Pack and Go to prevent unpacking without specifying a directory (which defaulted to the system32 folder).
25820	Pack and Go issues with unpacking projects from previous versions have been resolved to allow for easier upgrade.
21746	The Pack & Go Wizard now updates/replaces the node names in a Logging Server redundant configuration as expected.

Security

25427	There are now a number of new ways to lock down the AlarmWorX64 Viewer Acknowledgement Options within the Security Server.
23620	Active Directory Domain Accounts that belong to a Domain Group with a forward slash in the name will now be allowed.

Unified Data Manager

23574	Issues relating to Copy and Paste within the Unified Data Manager Configuration that caused copied folders and registers to become unusable have been fixed.
19777	The Propagation Settings within the Unified Data Manager for "Input Updates" could be ignored if "Refresh Outputs" was enabled, but this has been fixed.
25107	An issue in the Unified Data Manager that appeared in heavily nested folders has been fixed when using Import/Export functionality.

Workbench Silverlight

26016	Issues relating to the AssetWorX Navigator when the top asset is disabled have been fixed. This will allow clients like PortalWorX-SL to correctly display the Asset Navigator.
24636	An issue in the Workbench Silverlight sometimes caused an error dialog to appear without having a way to close it, but this has been fixed instead of forcing a refresh of the page.

Workbench Classic

11443	An issue where a save dialog appeared in the Workbench Classic even after applying changes (when no additional change was made) has been resolved.
-------	--

GENESIS64

General

26128 26132	Issues were seen in the Global Aliasing Engine and AlarmWorX64 Acknowledgement when upgrading from 10.61 to 10.70, but these issues have been fixed for 10.71.
----------------	--

AlarmWorX64

24218	An issue with the Default AlarmWorX64 Multimedia SMTP Mail Service has been fixed to suppress an exception that could occur.
25587	An issue within the AlarmWorX64 Logger indexes for archive tables has been fixed by optionally setting the Primary Key for archive tables.
19709	Support has been added in the AlarmWorX64 Logger to allow Global Aliasing within the Subscription String for Node Name in Event Points (Note: Aliasing is only supported for the Node Name).
24452	A missing help section relating to AlarmWorX64 configuration has been replaced and added to the general help document.
23774	It is now possible to highlight multiple alarms in the AlarmWorX64 Viewer.
25822	A Serialization issue has been resolved within the AlarmWorX64 Viewer caused an error in rare cases that could cause configurations with multiple tabs to appear incorrectly.
25560	An issue with printing AlarmWorX64 Viewer Reports has been resolved relating to printing preferences.
25532	An issue has been resolved in the AlarmWorX64 Viewer related to new alarms not changing the column header color to red when alarms are sorted by DateTime in Ascending order.
25494	An error in the API documentation incorrectly describes the Time Range Members TimestampOne and TimestampTwo by swapping their definitions. TimestampOne refers to the low value and TimestampTwo refers to the high value.
25453	Issues using the wildcard * in AlarmWorX64 Historical alarm filtering has been resolved in the AlarmWorX64 Viewer.
25451	Because IF THEN ELSE conditional statements are not allowed in generic SQL statements the option to add them to Historical AlarmWorX64 Filters has been removed.
24921	There was an issue fixed within the AlarmWorX64 Viewer that could cause incorrect filtering if a Node Filter was applied to Historical Alarms.
24523	The AlarmWorX64 Viewer Reporting has been updated to correctly show the Area in all cases for real-time subscriptions.
24221	An issue in the AlarmWorX64 Viewer that prevented Group headers from correctly display the column that has been used for grouping has been resolved.
22249	AlarmWorX64 Viewer Reports are now generated with local time instead of UTC time.
20323	An issue has been resolved regarding the way that AlarmWorX64 Active DA Alarm tags exposed their range property.
26330	It is now possible in the AlarmWorX64 Viewer to add multiple Subscriptions to AlarmWorX64 Servers.
20281	A check has been added in the AlarmWorX64 Configuration when importing from Excel where shared strings convert single occurrences of '\n' to '\r\n'. New lines will now be correctly imported.

25712	An issue with the AlarmWorX64 DA Server could cause bad OPC quality to be reported when trying to write to the DA value. This has been resolved in the AlarmWorX64 Server Configuration Database.
25102	Export issues found in the AlarmWorX64 Multimedia Configurator have been resolved to allow Import/Export of all items.

AssetWorX

26269	An issue with the way that some controls were using XAML caused an inability to rename the AssetWorX Navigator after an initial save. This has been fixed in the AssetWorX Navigator and both AnalytiX Viewers.
25869	An issue when logging in to the Security Server to view or change a Critical Point in the AssetWorX Navigator caused the selected Asset to change, but this has been resolved.

GraphWorX64

25268	A potential issue has been resolved for Local Aliasing within Smart Symbols where the alias would not resolve properly. To avoid issues the smart property must be bound to at least one property of a dynamic that can be a data source.
25807	WMF and EMF file import has been improved to cover a larger number of possible file contents.
25642	An issue was resolved that caused popup windows configured to launch as "Popup Window (Display Dependent - Modal)" were not appearing as modal in Internet Explorer, but they were in the GraphWorX64 desktop application.
25562	An issue with saving displays as Silverlight displays when using Smart Symbols containing Color based Smart Properties has been fixed. The issue could cause the Symbols to become partially transparent without this fix.
25309	An issue caused by canceling or undoing certain actions while working with the GraphWorX64 Pipe Control has been fixed preventing potential display corruption.
23708	A GraphWorX64 issue relating the keyboard "Backspace" button has been fixed to function as expected in more cases (a few cases caused more characters than intended to be erased).
8905	Updates to the GraphWorX64 Scale Control have been made to allow for finer grain control over spacing and text alignment.
24473	An issue with the Help documentation referring to the wrong syntax for using Local Aliases within a text box has been corrected. The correct format for a Text property in GraphWorX64 is <code>{{"<<alias>>"}}</code> .
22483 22484 22486	Improvements to the "Set Global Themes and Aliases Dialog" have been made in GraphWorX64 to allow for easier configuration.
26045	An issue has been fixed in GraphWorX64 when saving displays for Silverlight when they had embedded GraphWorX64 Viewer Controls. The issue would cause the border to disappear when saved, but it has been resolved.

24995	An issue with GraphWorX64 Publishing has been resolved to maintain referenced images in all cases based on error that has been removed regarding absolute and relative paths.
24993	An issue in GraphWorX64 Publishing has been fixed that could remove the path of an EXE name when you publish a display with a "Start Application" pick action.

GridWorX

25228	GridWorX Configurations using the Unified Data Manager Data Triggers on Data Refresh have been optimized for stability. Earlier versions could encounter communication problems with this scenario.
25758	An issue relating to the Schema Columns in the Advanced SQL Query Configuration in GridWorX has been fixed.
25540	User defined numbers for the number of records shown per page in the GridWorX Viewer Control were being ignored in some cases, but this has been resolved.
25539	A cosmetic issue has been fixed in the GridWorX Viewer Control could be found if the row height was increased at or above 200 pixels. This would cause some rows to not draw correctly.
25956	An issue that caused problems with writing to data sources within a GridWorX Write-enabled Data Source has been resolved.

ScheduleWorX64

25955	Users are now able to enter parameters to data sources like Value Sets when configuring schedules in ScheduleWorX64.
-------	--

TrendWorX64

23425	An issue where the Pen Status could show up as "Good" when tags were part of an OPC Server that was shut down has been linked to a timeout and has been solved.
25771	An issue with upgrading the TrendWorX64 Logger has been fixed to prevent an issue that could cause Logging to stop.
25929	Issues have been resolved regarding printing within the TrendWorX64 Viewer.
23217	An issue was fixed in the TrendWorX64 Viewer that could cause Global Aliases to not resolve when being viewer in the Legend.
23928	The Summary View in the TrendWorX64 Viewer has been updated to update more efficiently after changes are made to Pens in Freeze Mode.
25997	An option to allow use of the UTC Time Selection when exporting data from the TrendWorX64 Viewer has been added.
17231	TrendWorX4 Logger Database Import with Custom Configuration Name will now work properly even if the Configuration Name has been manually changed after export (it will be ignored on import to preserve compatibility).



Founded in 1986, ICONICS is an independent software developer of award winning real-time visualization, HMI/SCADA, manufacturing intelligence, building automation and energy/sustainability solutions. With over 250,000 installations worldwide, ICONICS products are used in automotive, building automation, oil & gas, pharmaceutical, renewable energy, utilities, water/wastewater, and many other applications.

ICONICS, a long standing Microsoft® Gold Certified Partner, utilizes the latest Microsoft technologies and is proud to be the winner of multiple awards for technology leadership. This includes receiving the 2012 Microsoft Sustainability Partner of the Year Award.

ICONICS cultivates an international culture of innovation, creativity and excellence in product design, development, technical support, sales and service. This has resulted in market leadership in advanced visualization, analytics, productivity and sustainability solutions. The company is headquartered in Foxborough, Massachusetts, USA with offices throughout the United States, Europe and Asia.

World Headquarters

100 Foxborough Blvd.
Foxborough, MA, USA, 02035
Tel: 508 543 8600
Email: us@iconics.com
Web: www.iconics.com

Czech Republic

Tel: 420 377 183 420
Email: czech@iconics.com

Italy

Tel: 39 010 46 0626
Email: italy@iconics.com

Germany

Tel: 49 2241 16 508 0
Email: germany@iconics.com

Netherlands

Tel: 31 252 228 588
Email: holland@iconics.com

France

Tel: 33 4 50 19 11 80
Email: france@iconics.com

UK

Tel: 44 1384 246 700
Email: uk@iconics.com

Australia

Tel: 61 2 9727 3411
Email: australia@iconics.com

China

Tel: 86 10 8494 2570
Email: china@iconics.com

India

Tel: 0091 22 67291029
Email: india@iconics.com



2012 PARTNER OF THE YEAR
Sustainability
Winner



Further information:
www.iconics.com/genesis64

